Borough of Somerville
Fire Prevention Bureau

25 West End Ave.
Somerville, NJ 08876
Fire Marshal Keith Thedinga
908-725-2300 x1968

Exit Sign and Emergency Light Log
N.J.A.C. 5:70-3, 604.1

Property Name _____

Property Address _____

MAINTENANCE REQUIREMENT: Tests shall be conducted monthly for 30 seconds and annually for 1 hour.

Date(s)	Unit #	Location	Results	Tested by

RETAIN THIS FORM ON THE PREMISES AND/OR SEND THE ANNUAL TEST COPY TO THE BUREAU OF FIRE PREVENTION